



# Government Gazette Staatskoerant

REPUBLIC OF SOUTH AFRICA  
REPUBLIEK VAN SUID-AFRIKA

*Regulation Gazette*

**No. 8928**

*Regulasiekoerant*

**Vol. 517**

**Pretoria, 18 July 2008**

**No. 31250**

*N.B. The Government Printing Works will not be held responsible for the quality of "Hard Copies" or "Electronic Files" submitted for publication purposes*



**AIDS HELPLINE: 0800-0123-22 Prevention is the cure**

---

**CONTENTS • INHOUD**

| <i>No.</i>   | <i>Page<br/>No.</i> | <i>Gazette<br/>No.</i> |
|--|---------------------|------------------------|
| <b>GOVERNMENT NOTICE</b>   |                     |                        |
| <b>Minerals and Energy, Department of</b>  |                     |                        |
| <i>Government Notice</i>   |                     |                        |
| R. 773 Electricity Regulation Act (4/2006): Electricity Regulations for Compulsory norms and Standards for Reticulation Services ..... | 2                   | 31250                  |

---

---

**GOVERNMENT NOTICE**

---

**DEPARTMENT OF MINERALS AND ENERGY****No. R. 773****18 July 2008****ELECTRICITY REGULATION ACT, 2006****ELECTRICITY REGULATIONS FOR COMPULSORY NORMS AND STANDARDS FOR  
RETICULATION SERVICES**

I, Buyelwa Sonjica, Minister of Minerals and Energy hereby, under section 35(4) of the Electricity Regulation Act, 2006 (Act No 4 of 2006), after consultation with the Regulator, Promulgate the regulations in the Schedule.

## SCHEDULE

1. **Definitions.** – In these Regulations, any word or expression to which a meaning has been assigned in the Act, shall have the meaning so assigned and, unless the context otherwise indicates –

“**building**” includes any other structure, whether of a temporary or permanent nature and irrespective of the materials used in the erection thereof, erected for or in connection with-

- (a) the accommodation or convenience of human beings or animals;
- (b) the manufacture, processing, storage, display or sale of any goods;
- (c) the rendering of any service;
- (d) the destruction or treatment of refuse or waste materials; or
- (e) the cultivation or growth of any plant or crop.

“**time of use**” means measurement of energy consumption on a time interval basis,

“**integrated power system**” means the interconnected network of electricity lines and equipment that connect the transmission, distribution and reticulation systems in South Africa;

“**the Act**” means the Electricity Regulation Act, 2006 (Act No. 4 of 2006),

“**smart system**” means an electricity meter that allows for –

- (a) measurement of energy consumed on a time interval basis,
- (b) two-way communication between the customer/end-user and the licensee,
- (c) storage of time interval data and transfer it remotely to the licensee, and
- (d) remote load management.

“**system operator**” means a licensed entity responsible for directing the operation and the reliability of the integrated power system

2. In order to maintain good quality of supply, to ensure stability of the electricity network, to minimise electricity load shedding and to avoid blackouts, the following norms and standards for reticulation services must be maintained in an area of jurisdiction-

- (a) In respect of lighting-
- (i) energy efficient fittings must be used in all buildings except where a specific fitting is required for some purpose and the nature of the purpose does not allow an energy efficient fitting;
  - (ii) street and highway lighting must be energy efficient and licensee must ensure that it is switched off during the day;
  - (iii) Street lights must be fitted with systems that allow for remote reduction of power especially during capacity constraints.
- (b) In respect of existing buildings, where an electric water heating facility is required-
- (i) a licensee should install a facility to remotely control the supply of electricity to any electric geyser that does not incorporate a solar heating water facility;
  - (ii) sub-regulation (b)(i) must be in place not later than 01 January 2012;
- (c) In respect of space heating, ventilation or cooling in existing buildings, to be in place not later than 01 January 2012, a licensee must-
- (i) install a facility to remotely control the supply of electricity to heating, ventilation and cooling system in its area of supply.
  - (ii) link a swimming pool drive and heating system to a facility that enables the licensee to remotely control its supply of electricity;
- (d) An end user or customer with a monthly consumption of 1000kWh and above must have smart system and be on time of use tariff not later than 01 January 2012;
- (e) Sub-regulations (b) and (c) do not apply in an event where the licensee can remotely reduce or increase the supply of electricity to the building using a smart system.

- (f) The System Operator and other licensee may only reduce the supply of electricity to customers during capacity or network constraints. Where the interruption is planned, the licensee must comply with the provisions of NRS 048 and inform affected customers at least a day before about the interruption of electricity supply.
- (g) In respect of sub-regulations (b) and (c) above, the licensee may remotely control the supply of electricity only during capacity or network constraints to avoid electricity blackouts. The System Operator must issue a notice to the licensee declaring the constraints in terms of network or capacity and requesting distributors to reduce demand.
-

**NOTICE TO:**

**SUBSCRIBERS**

**OF**

**GOVERNMENT GAZETTES**

Subscribers who have previously arranged to collect their weekly publications of *Government Gazettes* from the Government Printing Works in the Masada Building, are hereby requested to collect their publications from the Old Government Printing Works Building at the Security Officer's Bay at the Proes Street entrance, with effect from the 16th of October 2006.

We look forward to your ongoing support

Contact Person: **Montjane M. Z. (Mr)**

Mobile Phone: 083-640 6121.

Telephone: (012) 334-4653.

# Looking for out of print issues of Government and Provincial Gazettes

We can provide photocopies

## **Contact**

The National Library of South Africa,  
Pretoria Campus  
PO Box 397  
0001 PRETORIA

## **Physical address**

C/o Andries and Vermeulen Streets  
Entrance in Andries Street

## **Contact details**

Tel: (012) 321-8931  
Fax: (012) 325-5984  
E-mail: [infodesk@nlsa.ac.za](mailto:infodesk@nlsa.ac.za)

Printed by and obtainable from the Government Printer, Bosman Street, Private Bag X85, Pretoria, 0001  
Publications: Tel: (012) 334-4508, 334-4509, 334-4510  
Advertisements: Tel: (012) 334-4673, 334-4674, 334-4504  
Subscriptions: Tel: (012) 334-4735, 334-4736, 334-4737  
Cape Town Branch: Tel: (021) 465-7531

Gedruk deur en verkrygbaar by die Staatsdrukker, Bosmanstraat, Privaatsak X85, Pretoria, 0001  
Publikasies: Tel: (012) 334-4508, 334-4509, 334-4510  
Advertensies: Tel: (012) 334-4673, 334-4674, 334-4504  
Subskripsies: Tel: (012) 334-4735, 334-4736, 334-4737  
Kaapstad-tak: Tel: (021) 465-7531